



ठाणे महानगरपालिका
THE MUNICIPAL CORPORATION OF THE CITY OF THANE
प्रदूषण नियंत्रण कक्ष
POLLUTION CONTROL CELL



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,
चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas, Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 2801
Sample No. : Q1118

Date : 9 January 2025

Water Analysis Report

TMC/PCC/20/RO

753 ¹⁴
01/2025

Name Of the Organisation : M/S Saraswati Mandir Trust

Address : Naupada, M.G. Road, Thane (W)

E_mail ID : saraswatimandirtrustthane@gmail.com

Date of receiving Sample : 08 January 2025

Sample Collected by : Prabhakar Sonawale

Type of Water Sample : Storage Drinking (4th Sample)

Parameters	Results	Limits as per IS 10500
pH	7.20	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	2.0	5 NTU
Chloride	30.0	250 mg/L
Total Hardness	64.0	300 mg/L
Total Coliform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH.

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

9 Jan-25

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

9 Jan-25

Omsatyashiv Paralkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking (4th Sample) Water sample received to our Vakratunda Laboratory on 8/1/2025. Payment details given by TMC Representative i.e. Sample Collected Person is responsible for payment details. This further acknowledges that you have paid the charges Rs. 6380/- vide Receipt No.TMC/HQ/PLC/000141/23-24 dated 28.08.2024

This Report has been Signature Digitally.